

## Test report

### No. 20140916

**Applicant:** BONPET SYSTEMS d.o.o.  
Obrtniška cesta 30  
1420 TRBOVLJE  
SLOVENIA

**Manufacturer:** BONPET SYSTEMS d.o.o.  
Obrtniška cesta 30  
1420 TRBOVLJE  
SLOVENIA

**Application date:** 2014-06-20

**Subject of application:** Test of a premixed liquid fire extinguishing medium for suitability as fire extinguishing medium on use with fire extinguishers

**Name of the fire extinguishing medium:** Bonpet fire-extinguishing liquid

**Basis of the examination:** Test procedure instruction LM 01-01 of MPA Dresden GmbH dated 29<sup>th</sup> November 2011 for test of water based fire extinguishing media (following to EN 1568 and EN 3-7)

**Receipt of sample:** 2014-07-08

**Test laboratory:** MPA Dresden GmbH  
Official laboratory for fire extinguishing media and fire extinguishers  
Fuchsmühlenweg 6F  
09599 Freiberg  
GERMANY

This test report comprises 11 pages, including 1 annex.



**General information:**

Only equipment and materials detailed in this report have been subjected to the tests. Test results apply to the tested samples only.

This report may not be reproduced in parts without the written permission of the laboratory.

Publications of test reports and information on tests for publicity purposes need the written approval of the laboratory in every isolated case.

Every page of this report is stamped with the seal of the laboratory.

**Summary:**

The liquid fire extinguishing medium **Bonpet fire-extinguishing liquid** (premixed water based solution) has been tested relating to its chemical / physical characteristics and to its extinguishing efficiency in order to examine the suitability for fire extinguishing purposes.

The liquid extinguishing medium **Bonpet fire-extinguishing liquid** is suitable for application with fire extinguishers against fires of materials of the fire classes A, B and F according to EN 2.

The proof of the extinguishing effectiveness has been performed with portable stored pressure fire extinguishers (6 litres).

Test fire rating in accordance with EN 3-7 : 2004 + A1: 2007: **27 A, 144 B and 75 F**


Application concentration: undiluted application

Freezing point of the concentrate: -14,5 °C (measured on the sample)

**Special information:**

The marking label of the fire extinguishing medium for packing containers is to furnish with the required information (see on page 9, clause 5 of this test report).

26<sup>th</sup> August, 2014

  
Grad. Eng. Dittrich  
Laboratory Manager



  
Grad. Eng. Bauer  
Official